



中国国家强制性产品认证证书



证书编号: 2020322310002851

认证委托人名称: 图尔克(天津)传感器有限公司
认证委托人地址: 天津经济技术开发区渤海路34号
生产者名称: 汉斯图尔克有限公司
生产者地址: 鲁尔区米尔海姆威茨雷本大街7号
生产企业名称: 维尔纳尔图尔克有限公司
生产企业地址: Kirchloehrer Weg 7, 58553 Halver, Germany

产品名称: 总线模块

系列、规格、型号: TI41EX

标准: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
GB 12476.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020年10月15日

有效期至: 2025年10月14日

首次发证日期: 2020年10月15日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322310002851

APPLICANT: Turck (Tianjin) Sensor Co., Ltd.
ADDRESS: No.34 Bohai Road, TEDA, Tianjin, P.R.China
MANUFACTURER: Hans Turck GmbH & Co. KG
ADDRESS: Witzlebenstr. 7, 45472 Mülheim an der Ruhr
FACTORY: Werner Turck GmbH & Co.,KG
ADDRESS: Kirchloether Weg 7, 58553 Halver, Germany

PRODUCTNAME: excom module

SERIES,SPECIFICATION,MODEL: TI41EX

STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
GB 12476.4-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:October 15, 2020

Valid until: October 14, 2025

Date of original certification:October 15, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001882



中国国家强制性产品认证证书



证书编号: 2020322310002851

附 件

产品名称: 总线模块

型号规格: TI41EX

防爆标志: Ex ib [ia Ga] IIC T4 Gb; [Ex iaD]

电气参数: 当防爆型式为 Ex ib IIC 时, 需与 MT 系列 Module subrack 连接使用。

AC-supply:

最大值: $U=20VAC$, $f=300\sim314kHz$, $P=1W$, $C_i=0$, $L_i=0$

Field circuits:

该产品 4 个通道所对应的端子代号:

通道	端子代号	通道	端子代号
1	1~4	3	9~12
2	5~8	4	13~16

最高输出电压 U_o (V)	最大输出电流 I_o (mA)	最大输出功率 P_o (mW)	最大内部等效参数	
			C_i (μF)	L_i (mH)
5.3	4.5	6	1	2

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号: 2020322310002851

附 件

防爆组别与外部参数的关系如下表:

	II C	II B
Lo(mH)	Co(μ F)	Co(μ F)
3	1.6	12
2	2	15
1	2.5	18
0.5	3	22
0.2	4	29
0.1	5.1	37

批 准:



上海仪器仪表自控系统检验测试所有限公司